

CERTIFICATE OF FIRE APPROVAL

This is to certify that

The product detailed below will be accepted for compliance with the applicable Lloyd's Register Rules and Regulations and with the International Convention for the Safety of Life at Sea, (SOLAS), 1974, as amended, for use on ships and offshore installations classed with Lloyd's Register, and for use on ships and offshore installations when authorised by contracting governments to issue the relevant certificates, licences, permits etc.

Manufacturer	Rockwool A/S
Address	Hovedgaden 501 2640 Hedehusene Denmark
Type	A-60 DECK
Description	Aluminium Deck insulated on underside with "Rockwool Marine Firebatts 130"
Specified Standard	IMO Resolution MSC.61(67) - (FTP Code) Annex 1 Part 3 IMO MSC/Circ.1120

The attached Design Appraisal Document forms part of this certificate.

This certificate remains valid unless cancelled or revoked, provided the conditions in the attached Design Appraisal Document are complied with and the equipment remains satisfactory in service.

Date of issue	31 May 2011	Expiry date	30 May 2016
---------------	-------------	-------------	-------------

Certificate No.	SAS F110190
-----------------	-------------

Signed	
--------	--

Sheet No	1 of 3
----------	--------

Name	S. Abraham Surveyor to Lloyd's Register EMEA A Member of the Lloyd's Register Group
------	---

Note:

This certificate is not valid for equipment, the design or manufacture of which has been varied or modified from the specimen tested. The manufacturer should notify Lloyd's Register of any modification or changes to the equipment in order to obtain a valid Certificate.

"Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract."

DESIGN APPRAISAL DOCUMENT

Date 31 May 2011	Quote this reference on all future communications LDSO/TA/SFS/SA
---------------------	---

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F110190

This Design Appraisal Document forms part of the Certificate.

APPROVAL DOCUMENTATION

Danish Institute of Fire Technology, DIFT, (formerly DANTEST), Copenhagen, Denmark, Fire Test Report No. PG 10765, dated 3 October 2000.

CONDITIONS OF CERTIFICATION

1. When used in conjunction with an aluminium deck to maintain a maximum core temperature of 200°C.
2. Consisting of: an aluminium structural deck insulated on the underside with two layers of (30mm thick, 130kg/m³ density) "Rockwool Marine Firebatts 130" with staggered insulation joints and retained to the substrate by 3mm diameter steel pins and steel washers spaced at 300mm maximum centres and maximum 10mm from all edges.
3. Insulated face of the division to be exposed to the fire side in all cases.
4. Production items are to be manufactured in accordance with a quality control system which shall be maintained to ensure that items are of the same standard as the approved prototype.

PLACES OF PRODUCTION

Rockwool A/S
2640 Hedehusene
Vamdrup
Doense
Denmark

Rockwool A/S
Moss
Trondheim
Norway

Rockwool Polska Sp. z.o.o.
66-131 Cigacicie
Poland

Deutsche Rockwool GmbH & Co. OHG
Flechtingen
Neuburg
Gladbeck
Germany

Rockwool BV
NL-6045 JG Roermond
The Netherlands

Rockwool France
63700 Saint Eloy Les Mines
France

DESIGN APPRAISAL DOCUMENT

Date

31 May 2011

Quote this reference on all future communications

LDSO/TA/SFS/SA

ATTACHMENT TO CERTIFICATE OF TYPE APPROVAL No. SAS F110190

PLACES OF PRODUCTION continued

Roxul Asia Sdn. Bhd.
75450 Melaka
Malaysia

Flumroc AG
8890 Flums
Switzerland

Rockwool Adriatic d.o.o.
52 333 Potpićan
Croatia

Rockwool Peninsular S.A.U.
E-31380 Caparrosa
Spain

Rockwool Hungary
8300 Tapolca
Hungary
Poland



Saji Abraham
Surveyor
Statutory Fire & Safety
London Design Support Office
Lloyd's Register EMEA

Supplementary Type Approval Terms and Conditions

This certificate and Design Appraisal Document relates to type approval, it certifies that the prototype(s) of the product(s) referred to herein has/have been found to meet the applicable design criteria for the use specified herein, it does not mean or imply approval for any other use, nor approval of any products designed or manufactured otherwise than in strict conformity with the said prototype(s).